

AMENDATORY SECTION (Amending WSR 01-02-026, filed 12/22/00, effective 1/22/01)

WAC 296-96-02355 What are the installation and operation requirements for hall buttons? (1) The centerline of all hall call buttons must be 42 inches above the floor.

(2) The "UP" direction button must be on top.

(3) Raised or flush direction buttons, exclusive of the panel border, must be a minimum of 3/4 inch in size.

(4) Indicator lights must be installed to show each call registered and they must extinguish when the call is answered.

(5) When pushed, the depth of flush buttons must not exceed 3/8 inch.

Exception: Special purpose and residential elevators are exempt from this section.

Note: The exception becomes effective August 20, 2004.

NEW SECTION

WAC 296-96-23303 What requirements apply to hydraulic elevators without safety bulkheads? (1) Oil levels must be monitored and tracked in a log.

(2) The log must contain the date the oil was added, the reason for the loss of oil, and the amount of oil added.

(3) If the reason for the loss of oil cannot be determined, the unit must be immediately taken out of service and the cylinder must be replaced.

Note: This section becomes effective August 20, 2004.